

CERTIFICATE

No. U6 097674 0018 Rev. 01

Holder of Certificate: **Koopman Interlight**
Molenvliet 2
3961MV Wijk bij Duurstede
The Netherlands

Certification Mark:




Product: **Power supplies
(LED Driver)**

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64142205002502

Date, 2021-04-09



(Taylor Yao)



CERTIFICATE

No. U6 097674 0018 Rev. 01

Model(s): IL-D14DALI2L
IL-D48DALI2L

Brand Name: LEDGEAR, INTERLIGHT



Parameters:

Rated Input Voltage: 220-240VAC
Rated Frequency: 50/60Hz
Rated Input Current: See below table for details
Rated Output: See below table for details
Protection against Electric Shock: Class II; SELV
Degree of Protection: IP20
Method of Installation: Independent
Type of Output: Constant current type
ta: See below table for details
tc: See below table for details



Product Service

CERTIFICATE

No. U6 097674 0018 Rev. 01

| Model | Rated Input Current (A Max.) | Output Voltage (VDC) | I _{rated} (mA) | U _{out} (VDC) | P _{rated} (W) | Value of ta; tc (°C) |
|--------------|------------------------------|----------------------|-------------------------|------------------------|------------------------|----------------------|
| IL-D14DALI2L | 0.1 | 14-40 | 120 | 49 | 4.8 | 55; 80 |
| | | | 160 | | 6.4 | |
| | | | 180 | | 7.2 | |
| | | | 220 | | 8.8 | |
| | | | 250 | | 10 | |
| | | | 280 | | 11.2 | |
| | | | 350 | | 14 | |



Product Service

CERTIFICATE

No. U6 097674 0018 Rev. 01

| | | | | | | |
|--------------|-----|-------|------|----|------|--------|
| IL-D48DALI2L | 0.3 | 14-42 | 650 | 49 | 27.3 | 50; 85 |
| | | | 700 | | 29.4 | |
| | | | 750 | | 31.5 | |
| | | | 800 | | 33.6 | |
| | | | 850 | | 35.7 | |
| | | | 900 | | 37.8 | |
| | | | 950 | | 39.9 | |
| | | | 1000 | | 42.0 | |
| | | 14-38 | 1050 | | 39.9 | 45; 85 |
| | | | 1100 | | 41.8 | |

Tested according to:

EN 61347-2-13:2014/A1:2017
EN 61347-1:2015/A1:2021
EN 62384:2006/A1:2009

Production Facility(ies):

097674

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICAT